	Barrier Removal Schedule: Estimated project cost = \$400,000 Renovation of 105 Toilet Rm. #2 = \$25,000 Renovation of 114 Kitchen = \$30,000 Installation of tactile signage = \$4000 Total cost of barrier removal items = \$59,000 Percentage of overall project = 15%	Sound transmission: Air-borne between dwelling unit and other occupancies: STC of 50 or greater. This is a renovation project with no change in area, no change in occupancy, and no changes to the walls separating the occupancies. Therefore requirement is not applicable. Structure-borne at floor-ceiling assemblies between dwelling unit and other occupanes: IIC of 50 or greater. Not applicable in a single-story building.	 Building envelope fenestration Entrance door Min U = (Existing) New windows Min U = .35, Max SHGC = .40 Rollup doors Min U = 0.50, Max SHGC = .40 New exterior wall (south) = R-21 Attic = (Existing) No insulaton change to un-modified walls. Fill any exposed existing wall cavities with fiberglass batt insulation. 	Barrier Removal (up to 25% of project cost): When complete building will be accessible. Note that parking and access to the building are in the right-of-way.	Plumbing Fixtures: R-2: (dwelling unit): Self-contained. B and S occupancy: Toilet 1 per 25 occ. = 1, Lavatory 1 per 40 occ. = 1	Corridor Rating: R, B and S occ.: Non-rated under quantity of occupants listed in (T1018.1).	Egress lighting not required (1006.3.2).	Single exit floor travel distance max. w/sprinkers: B = 100' S-1 = 100' (T1021.2(2)), actual = 96' R-2 (dwelling unit) w/sprinklered = 125' (T1021.2(1)), actual = 53'.	Exits: Distance to Exit before two exits are required: B and S occ. max. = 100', actual = 96' (Sprinklered) R-2 occ. max. = 125', actual 53'. Therefore CPET not applicable. (T1014.3)	Occupant load: 29 (See Code Plan).	Required separations: Between dwelling unit and S-1 = 1/2 Hr. Between dwelling unit and B = 1/2 Hr. (420.2, 708.3 Ex. 2). Between S-1 and B = 0-Hr.	Allowable floor area: 7000 square feet (limit set by R-2 occupancy).	Total building area: 3266 square feet.	Building setbacks: Front (street side): 10' Side, rear: None.	Building Height: Allowable (OSSC): 1 story, 40 feet (Basic based on non-separated occupancy (S-1 sets limit)) / 2 stories, 50' (Sprinklered).	Construction Type: V-B, sprinklered to NFPA13. Currently the building is not fire sprinklered but will be as part of this project.	Occupancy classification: R-2 / S-1 / B. Mixed-use, non-separated.	Applicable building code: Oregon State Structural Specialty Code (latest edition)	Zone classification: Not applicable (Federal land).	Local Jurisdiction: United States Forest Service	Site area:	Project Description: Renovate building interior. No site work other than driveway work at new south side foundation and apparatus bay.		
--	--	--	--	--	---	--	--	--	--	---------------------------------------	--	--	--	---	--	--	---	--	--	---	------------	--	--	--



